

PROPOSED POWER EVACUATION ARRANGEMENT FOR FORTH COMING WIND POWER PROJECTS (RECOMMENDED TO MSETCL/ MSEDCL) 09-10							
Sr. No.	Project site	Tal.	Dist.	Capacity in MW	Proposed work	Ref. letter No. Date	
1	Vankusawade (Sadavaghapur, Jambhekarwadi)	Patan	Satara	10	Proposed 10 MW wind power will be connected at existing 220/33 KV S/S at Vankusawade of MSETCL by constructing – a) 9 kms 33 KV Single Circuit line by using 0.1 ACSR DOG conductor from proposed wind farm site at Sadavaghapur, Jambhelkarwadi area near Vankusawade windy site to existing 220/33 KV S/S at Vankusawade of MSETCL. b) One no. of 33 KV bay at existing 220/33 KV S/S at Vankusawade of MSETCL. c) The suitable metering arrangement will be made by Developer.	GCR-2009/SUZLON-10MW VANKUSWADE (27) S/S/CR-01/IDD/2041 dtd. 27.4.09	
2	Kavadya Dongar, (Kavadya Dongar, Shajapur, Bhoyre Pathar)	Parner	Ahmednagar	15	Proposed 15 MW wind power will be connected at existing 132/33 KV S/S at Supa of MSETCL by constructing – a) 10 kms 33 KV Single Circuit Panther line from proposed wind farm site at Kavadya Dongar, Shajapur, Bhoyre Pathar area near Kavadya Dongar windy site to existing 132/33 KV S/S at Supa of MSETCL. b) One no. of 33 KV bay at existing 132/33 KV S/S at Supa of MSETCL. c) The suitable metering arrangement will be made by Developer.	GCR-2009/SUZLON-15MW KAVADYA DONGAR(13)S/S/CR-2/IDD/10831 dt.24/4/2009	
3	Bhud, (Revangaon, Lengare, Dhonggewadi, Bhud)	Khanapur	Sangali	10	a) Proposed additional 10MW wind power at Revangaon, Lengare, Dhonggewadi, Bhud area near Bhud windy site will be transmitted through existing newly constructed 1no. 33kv D/C & S/C lines from Bhud site to existing 220/33KV Vita S/stn of MSETCL	IDD 2009/CR-/10MW/BHUD/09-10/V.W.T.I.P.L.-1/3322 dt.25/5/2009.	
4	Vedganga, (Megholi, Korivade, Harapade, Bidari, Bediv, Varapewadi, Manavale, Pernoli & Vicinity Area)	Gargoti - Bhudargad, Ajara, Gadhinglaj;	Kolhapur	200	Proposed 200 MW wind power will be connected to LILO arrangement proposed on 220 KV SCOH Talandge – Sawantwadi EHV line by MSETCL by constructing – a) Proposed 220/33 KV, 2 x 100 MVA transformer at Gargoti S/S (Tentative) area near Vedganga windy site. b) Approx. 15 kms, 220 KV D/C OH line (For LILO) on Tower by using 0.4 ACSR conductor from proposed 220/33 KV, 2 x 100 MVA transformer at Gargoti (Tentative) S/S area near Vedganga windy site to proposed 220 KV SCOH Talandge – Sawantwadi EHV line by MSETCL. c) Two no. of 220 KV outgoing line bays & 14 nos. of 33 KV incoming line bays at proposed 220/33 KV, 2 x 100 MVA transformer at Gargoti (Tentative) S/S area near Vedganga windy site. d) The suitable metering arrangement will be made by Developer.	GCR-2009/ENERCON-200MW/VEDGANGA/CR-4/IDD/1882 dt.16/4/2009	

5	Motha, (Aldoha, Lawada & Shahapur Vicinity)	Chikhaldara	Amravati	10	Proposed 10 MW wind power will be connected at existing 33/11 KV S/S at Chikhaldara of MSEDCL by constructing – a) 3 kms 33 KV Single Circuit line by using 0.1 ACSR DOG conductor from proposed wind farm site at Aldoha, Lawada & Shahapur Vicinity area near Motha windy site to existing 33/11 KV S/S at Chikhaldara of MSEDCL . b) One no. of 33 KV bay at existing 33/11 KV S/S at Chikhaldara of MSEDCL. c) The suitable metering arrangement will be made by Developer.	GCR-2009/SHRIRAM-10MW MOTHA/CHIKHALDAR S/S/CR-02/IDD/2039 dt.27/4/2009
6	Motha,(Aldoha, Lawada & Shahapur)	Chikhaldara	Amravati	10	Proposed 10 MW wind power will be connected at existing 33/11 KV S/S at Chikhaldara of MSEDCL by constructing – a) 3 kms 33 KV Single Circuit line by using 0.1 ACSR DOG conductor from proposed wind farm site at Aldoha, Lawada & Shahapur area near Motha windy site to existing 33/11 KV S/S at Chikhaldara of MSEDCL . b) One no. of 33 KV bay at existing 33/11 KV S/S at Chikhaldara of MSEDCL. c) The suitable metering arrangement will be made by Developer.	GCR-2009/SHRIRAM-10MW MOTHA/CHIKHALDAR S/S/CR-03/IDD/2040 dt.27/4/2009
7	Sautada,(Mugga oan, Antapur & Vicinity)	Patoda	Beed	10	Proposed 10 MW wind power will be connected at existing 33/11 KV S/S at Pokhari of MSEDCL by constructing – a) 9 kms 33 KV Single Circuit line by using 0.1 ACSR DOG conductor from proposed wind farm site at Mugga oan, Antapur & Vicinity area near Sautada windy site to existing 33/11 KV S/S at Pokhari of MSEDCL . b) One no. of 33 KV bay at existing 33/11 KV S/S at Pokhari of MSEDCL. c) The suitable metering arrangement will be made by Developer.	GCR-2009/SHRIRAM-10MW SAUTADA (23)/POKHARI S/S/CR-01/IDD/2042 dt.27/4/2009
8	Bhud,(Jakhindwadi, Gorewadi, Jadhavwadi, Dhorawadi, Balvandi, Mengoanwadi, Bhud Lengre, Madhakmuli)	Khanapur	Sangali	100	Proposed 100 MW wind power will be connected at LILO on 110 KV Karad to Pandharpur EHV line of MSETCL by constructing – a) Proposed 2x50 MVA 110/33 KV sub-station at Bhud windy site b) 13 kms 110/33 KV D/C line by using Panther ACSR conductor from proposed 2x50 MVA, 110/33 KV sub-station at Jakhindwadi, Gorewadi, Jadhavwadi, Dhorawadi, Balvandi, Mengoanwadi, Bhud Lengre, Madhakmuli area near Bhud windy site to LILO on existing 110 KV Karad - Pandharpur EHV line of MSETCL.. c) The suitable metering arrangement will be made by Developer.	IDD 2008/CR-100MW/BOTHE/SRIMARUTI-2035 dt.27/4/2009.
9	Bhud,(Kurunwadi (Part Of Land), Jalki Taraswadi, Pimpri Budruk,)	Atpadi	Sangali	10	Proposed 10 MW wind power will be connected at 33/11 KV S/S at Jhare of MSEDCL by constructing – a) 10 kms 33 KV S/C line by using 0.1 ACSR DOG conductor from proposed wind farm site at Kurunwadi (Part Of Land), Jalki Taraswadi, Pimpri Budruk area near Bhud windy site to 33/11 KV S/S at Jhare of MSEDCL.	GCR-2009/SHRIMARUTI-10MW BHUD/JHARES/S/CR-37/IDD/2030 dt.27/4/2009

					<p>b) One no. of 33 KV bay at 33/11 KV S/S at Jhare of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer.</p>	dt.27/4/2009.
10	Bhud,(Vibutwadi(Part of land),Kurundwadi(Part of land), Jalki Taraswadi, Pimpri Budruk And Vicinity)	Atpadi	Sangli	10	<p>Proposed 10 MW wind power will be connected at existing 33/11 KV S/S at Vikhale of MSEDCL by constructing –</p> <p>a) 10 kms 33 KV Single Circuit Dog line from proposed wind farm site at Vibutwadi(Part of land),Kurundwadi(Part of land), Jalki Taraswadi, Pimpri Budruk And Vicinity area near Bhud windy site to existing 33/11 KV S/S at Vikhale of MSEDCL.</p> <p>b) One no. of 33 KV bay at existing 33/11 KV S/S at Vikhale of MSEDCL .</p> <p>c) The suitable metering arrangement will be made by Developer..</p>	GCR-2009/SRIMARUTI-10MW BHUD (30) S/S/CR-36/IDD/2037 dt.27/4/2009.
11	Ambheri,(Visapur (Part Of Land), Khelkarwadi,)	Khatav	Satara	10	<p>Proposed 10 MW wind power will be connected at 110/33/22 KV S/S at Satara Road of MSEDCL by constructing –</p> <p>a) 16 kms 33 KV S/C line by using 0.1 ACSR DOG conductor from proposed wind farm site at Visapur (Part Of Land), Khelkarwadi area near Amberi windy site to 33/22 KV S/S at Satara Road of MSEDCL.</p> <p>b) One no. of 33 KV bay at 110/33/22 KV S/S at Satara Road of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer.</p>	GCR-2009/SHRIMARUTI-10MW AMBHERI/SATARR DS/S/CR-35/IDD/2036 dt.22/4/2009.
12	Gudepanchagani ,(Part of Gandoli, Malewadi, Virale, Thavade, Jambur, Charan, Charanvadi, Shetakvadi, and Part of Malegaon)	Shahuwadi,	Kolhapur	10	<p>Proposed 10 MW wind power will be connected to 33/22 KV S/S at Thavade of MSEDCL by constructing –</p> <p>a) 5 kms 33 KV Single Circuit RJS pole line by using 0.1 ACSR DOG conductor from proposed wind farm site at Part of Gandoli, Malewadi, Virale, Thavade, Jambur, Charan, Charanvadi, Shetakvadi, and Part of Malegaon area near Gudepanchagani windy site to existing 33/22 KV S/s at Thavade of MSEDCL .</p> <p>b) One no. of 33 KV bay at existing 33/22 KV S/s at Thavade of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer.</p>	GCR-2009/TSWPD-10MW Gude.10/Thavade S/S/CR-27/IDD/2031 dt.24/4/2009
13	Kas,(Ganje, Galdev, Mahate khurd, Aalwadi, Waki, Nipani, Aapati & Gondemal, Warsoli Koli & Rameghar)	Jawali & Mahabeleshwar	Satara	10	<p>Proposed 10 MW wind power will be connected at existing 33/22 KV S/S at Medha of MSEDCL by constructing –</p> <p>a) 7 kms 33 KV Single Circuit RJS pole line by using 0.1 ACSR DOG conductor from proposed wind farm site at Ganje, Galdev, Mahate khurd, Aalwadi, Waki, Nipani, Aapati & Gondemal, Warsoli Koli & Rameghar area near Kas windy site to existing existing 33/22 KV S/S at Medha of MSEDCL.</p> <p>b) One no. of 33 KV bay at existing 33/22 KV S/S at Medha of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer..</p>	GCR-2009/TSWPD-10MW Kas 12/Medha S/S/CR-28/IDD/2034 dt.24/4/2009

14	Gudepanchagani, (Yenpe, Matekarwadi, Akaiwadi, yelgaon, Gotewadi Tal-Karad Dist-Satara and Shirshi, Kondewadi, Girjawade, meni, yelapur, hategaon, wakurde budrak)	Sirala & Karad	Sangli & Kolhapur	10	<p>Proposed 10 MW wind power will be connected at existing 33/11 KV S/S at Undale of MSEDCL by constructing –</p> <p>a) 5 kms 33 KV Single Circuit RJS pole line by using 0.1 ACSR DOG conductor from proposed wind farm site at Yenpe, Matekarwadi, Akaiwadi, yelgaon, Gotewadi Tal-Karad Dist- Satara and Shirshi, Kondewadi, Girjawade, meni, yelapur, hategaon, wakurde budrak area near Gudepamnchgani windy site to existing 33/11 KV S/S at Undale of MSEDCL .</p> <p>b) One no. of 33 KV bay at existing 33/11 KV S/S at Undale of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer.</p>	GCR-2009/TSWPD-10MW Gude.10/UndaleS/S/CR-29/IDD/2033 dt.24/4/2009
15	Thoseghar, (Thoseghar, Rakuslewadi, Bendwadi, Rajapuri, Vavdare, Revande & Panghare Tal- & Dist- Satara.)	Satara	Satara	5	<p>Proposed 5 MW wind power will be connected at 33/22 KV S/S at Parli of MSEDCL by constructing –</p> <p>a) 7 kms 33 KV Single Circuit RJS line by using 0.1 ACSR DOG conductor from proposed wind farm site at Thoseghar, Rakuslewadi, Bendwadi, Rajapuri, Vavdare, Revande & Panghare area near Thoseghar windy site to existing 33/22 KV S/s at Parli of MSEDCL.</p> <p>b) One no. of 33 KV bay at existing 33/22 KV S/s at Parli of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer.</p>	GCR-2009/TSWPD-5MW Thpseghar (25)/ParliS/S/CR-30/IDD/2032 dt.24/4/2009.
16	Kas, (Ganje, part of Galdev, Mahate khurd, Nipani, Aпти, Gondemal, Warsolikoli, Sangvi, Kusumbi.)	Jawali	Satara	10	<p>Proposed 10 MW wind power will be connected at existing 33/22 KV S/S at Tapola of MSEDCL by constructing –</p> <p>a) 7 kms 33 KV Single Circuit 0.1 Dog conductor from proposed wind farm site at Ganje, Part of Galdev, Mahate Khurd, Nipani, Aпти, Gondemal, Warsolikoli, Sangvi, Kusumbi, Kas windy site to existing 33/22 KV S/S at Tapola of MSEDCL.</p> <p>b) One no. of 33 KV bay at existing 33/22KV S/S at Tapola of MSEDCL.</p> <p>c) The suitable metering arrangement will be made by Developer..</p>	GCR-2009/TSWPD-10MW KAS/TAPOLA S/S/CR-5/09-10/IDD Date: 23.6.2009