

## Observations and Suggestions of

### “ Wind Zone Classification and Evaluation Committee”

➤ **Developer:- M/s. Sriram EPC Ltd.**

- *Site:- Sautada, Tal. Patoda, Dist. Beed (Vetted by NIWE Chennai).*
- *Investor:- Shiv Renewable Energy Pvt.Ltd., Mumbai 2.75 MW (11x250KW)*  
The project is commissioned during the financial year .

**observations:-**

- Nearest reference Wind Mast mentioned for the above mentioned wind power project is at location . Sautada, Tal. Patoda & Dist.Beed (Latitude- **N 18° 47' 52"** Longitude- **E 75° 20' 14"** Elev.- 790m amsl) having **WPD- 223watt/m<sup>2</sup> @ 50 m AGL** declared by NIWE Chennai for MEDA.
- Joint Inspection not observed
- Commissioning report issued by MSEDCL is not submitted

**Suggestions:-**

- Complete Joint Inspection work with MEDA and developers / Investors representative report is not submitted.
- Submit Commissioning report issued by MSEDCL

**Developer:- M/s. Regen Powertech Pvt.Ltd.**

- *Site:- Isapur, Tal. Pusad, Dist. Yawatmal (Vetted by NIWE Chennai).*
- *Investor:- M/s.Hetro Med Solutions Ltd Hyderabad :- 10.50 MW (17x1500KW)*

**observations:-**

- Nearest reference Wind Mast mentioned for the above mentioned wind power project is at location *Site:- Isapur, Tal. Pusad, Dist. Yawatmal* (Latitude- **N 19° 43' 56.7"** Longitude- **E 77° 27' 18.5"** Elev.- 439 m amsl) having **WPD- 200 watt/m<sup>2</sup> @ 50 m AGL** declared by NIWE Chennai for MEDA.
- Joint Inspection not observed

**Suggestions:-**

- Complete Joint Inspection work with MEDA and developers / Investors representative.

**Developer:- M/s. K.P.Power Pvt.Ltd.**

- *Site:- Pedhewadi, Tal. Akole, Dist.Ahmednagar (Vetted by NIWE for M/s Gamesa Wind Turbines Pvt. Ltd.Chennai).*
- *Investor:- M/s.SJVN Ltd.:- 2.55 MW (3x850KW)*

**Observations:-**

- Nearest reference Wind Mast mentioned for the above mentioned wind power project is at Village . *Pedhewadi, Tal. Akole, Dist.Ahmednagar* (Latitude-  $N19^{\circ}40'59.2''$  Longitude-  $E 73^{\circ}52'43.5''$  Elev.- 1047 m amsl) having **WPD- 218.39 W/m<sup>2</sup> @ 50 m AGL** vetted by NIWE Chennai for *M/s Gamesa Wind Turbines Pvt. Ltd.Chennai* their Report on Verification of Procedure of Wind Monitoring at *Pedhewadi, Tal. Akole, Dist.Ahmednagar*.
- Joint Inspection not observed

#### **Suggestions:-**

- Complete Joint Inspection work with MEDA and developers / Investors representative report is not submitted.
- **Developer:-M/s. Karma Energy Ltd.**
- **Site:-** *Sundi, Tal. Chandgad, Dist. Kolhapur, (Vetted by NIWE for M/s Dahivel Energy Pvt Ltd, Mumbai).*
- **Investor:-** *M/s.Clean Wind Power Pvt Ltd:- 3.60 MW (6x0.600KW)*

#### **observations:-**

Nearest reference Wind Mast mentioned for the above mentioned wind power project is at Village . *Sundi, Tal. Chandgad, Dist. Kolhapur* (Latitude-  $N15^{\circ}53'54.1''$  Longitude-  $E 74^{\circ}22'57''$  Elev.- 990 m amsl) having **WPD- 249.75 W/m<sup>2</sup> @ 50 m AGL** vetted by NIWE Chennai for *M/s Dahivel Energy Pvt Ltd, Mumbai* their Report on Verification of Procedure of Wind Monitoring at *Sundi, Tal. Chandgad, Dist. Kolhapur*.

- Joint Inspection report is not observed.
- Commissioning Certificate issued by MSEDCL is not submitted.
- Undertaking in prescribed format is not observed.

#### **Suggestions:**

- Complete Joint Inspection work with MEDA and developers / Investors representative.
- Submit Commissioning report issued by MSEDCL and Undertaking in prescribed format.

